



# **Water Update**

## ***Overview of Water System & Current Projects***

**Justin Shobe, PE – District Water Engineer**

**June 5, 2019**



**Luhdorff &  
Scalmanini**  
Consulting Engineers

# Topics

- 1. Water System Overview**
- 2. Well 2 and Well 4A Rehabilitations**
- 3. Well 8 Alternatives Study**
- 4. Laguna Court Pipeline Crossing Break**
- 5. PLC and SCADA Upgrades for Newport Drive WTP**





# Water System



Booster

## Water System Description



The Town's water is supplied from groundwater aquifers that exist in the earth's crust. There are six wells within the Town that extract groundwater for public consumption. Prior to delivery, the water is treated at two water treatment plants where it is filtered to remove iron and manganese from the water supply for aesthetics, and chlorinated for disinfection.

Well Information			
Well	Water Treatment Plant	Year Installed	Capacity [Gallons Per Minute]
1B	Willow Lake	1995	1000
2	Willow Lake	1971	800
5	Willow Lake	2009	1,700
4A	Newport	1996	1800
5A	Newport	1991	2000
7	Newport	2014	1800

Water System Information		
	Existing	Build Out
Population	14,608	18,500
Service Connections	3,947	6,954
Annual Production (Million Gallons)	861	1,372
Average Demand Per Capita (GPCD) (2000-2020)	261	209 (2000 target)


Source: 2015 Urban Water Management Plan

## Map Legend






# Groundwater in Discovery Bay




# Groundwater in Discovery Bay

## Well Design Criteria


MONITORING WELL LITHOLOGY



MONITORING WELL ELECTRICAL LOG



WELL NO. 6 PRODUCTION WELL PROFILE



CENTRALIZER SCHEDULE		
SURFACE CASING	CONDUCTOR CASING	PRODUCTION CASING
5'	15'	30'
25'	55'	110'
	96'	190'
	130'	270'
	150'	300'
	175'	350'




# Wells in Discovery Bay

	Well 1B	Well 2	Well 6	Well 4A	Well 5A	Well 7
Year Well Drilled (age)	1995 (24 yrs)	1971 (48 yrs)	2009 (10 yrs)	1996 (23 yrs)	1991 (28 yrs)	2014 (5 yrs)
Year Pump Installed (pre-rehab)	2012	2003	2010	2001	2004	2015
Well Depth (ft)	350 ft	348 ft	360 ft	357 ft	357 ft	346 ft
Pump Design Flow	1600 gpm	850 gpm	1700 gpm	1800 gpm	2000 gpm	1800 gpm
Type	Submersible	Oil Lube	Submersible	Submersible	Water Lube	Submersible
WTP Serviced	Willow	Willow	Willow	Newport	Newport	Newport



# Well 2 and Well 4A Rehabs

Well Specific Capacity Records



Well 4A had consistent decline, 40% reduction over life. Post-Rehab capacity restored by 10%.


Well 2 and Well 4A efficiencies dropped below safe levels. Indicates age and wear of pumps. Post-Rehab efficiencies brought to “new pump” conditions.

Electrical Efficiency





# Well 2 and Well 4A Rehabs







## Well 8 Alternatives



**Luhdorff &  
Scalmanini**  
Consulting Engineers


# Well 8 Alternatives

Project #	Description	CIP Budget
CIP#52	<b>Well 8</b> - new 1,800 gpm supply well to replace Well 5A	\$2.2M
CIP#61	<b>Water Storage at Newport WTP</b> – a third 275,000-gallon tank to meet peak flows at Build Out.	\$1.0M
CIP#55/ 57	<b>Filter at Willow WTP</b> – a fourth filter increasing treatment by 850 gpm to meet maximum day demand at Build Out.	\$0.7M
<b>Total</b>		<b>\$3.9M</b>



# Well 8 Alternatives


## Storage at Newport WTP





# Well 8 Alternatives

## Filter at Willow WTP





# Well 8 Alternatives

## Well 8 “Stand-Alone” Concept:

- Treats water onsite using a filter.
  - Eliminates the Filter CIP at Willow Lake.
- Delivers straight to the distribution system.
  - Could eliminate the Storage CIP at Newport, (modeling is underway to study this).
- Provides a third source of water to the system.
  - Increases WTP redundancy.
- Anticipating a savings to the current CIP.
  - Cost Estimate feasibility are under investigation.





## Laguna Court Underwater Crossing Break




**Luhdorff &  
Scalmanini**  
Consulting Engineers



# Laguna Court Crossing Break

- On February 20 the underwater crossing on Laguna Court broke.
- The crossing was isolated on both sides, no services were impacted.
- There are 11 underwater crossings in the system.
- They provide hydraulic “looping” to meet Fireflows and avoid dead-ends.
- Modeling was conducted to study the hydraulics of this crossing out-of-service.
- Staff are currently investigating the cause of the leak and logistics for repair or replacement.







# Laguna Court Crossing Break

**Staff are exploring options to investigate the crossing and determine repair or replacement strategy and cost.**

1. Diver inspections – buried pipe has challenges.
2. Corrosion inspections from surface pothole.
3. Pipe camera inspections.
4. In-situ repairs either underwater clamps or internal lining.
5. Trenchless methods such as pipe bursting, horizontal drilling.
6. Cofferdam open trench replacement.
7. Install on lakebed (no trench).







## PLC and SCADA Upgrades at Newport WTP



**Luhdorff &  
Scalmanini**  
Consulting Engineers

# PLC and SCADA Upgrades for Newport WTP

**ON BUDGET**

**ON SCHEDULE**

**NO ISSUES**

**Status: final retention will be released pending approval of final programming and O&M documentation.**

